



INSERT THE FOLLOWING TEXT IN THE OPTIONS AND MODIFICATIONS SECTION OF THE SPECIFICATIONS:

COMPARTMENT MOUNTING KIT

SLIDE-OUT TRAY

A steel rollout equipment tray shall be installed in the specified compartment. The 600 pound (275 kg) rated tracks shall have sealed roller bearings with steel angle framework. The unit shall roll fully out of the compartment, with a device to hold trays in both the "in and out" positions. A warning label shall be installed on the firefighting assembly "WARNING: Slide tray must be extended for operation."

The location of the tray shall be in compartment # _____.

WATER TANK SUPPLY LINE

A 1.25" (31 mm) water tank to fire pump line shall be installed as follows:

- From the fire pump to the water filter shall be a 1.25" (31 mm) flexible transparent hose.
- 15' (5 m) of 1.25" (31 mm) flexible water hose with removable connections and clamping devices.
- One (1) 1.25" (31 mm) electrically operated two-way tank to pump control valve.